



CITY OF MANTECA

PUBLIC WORKS DEPARTMENT WATER DIVISION

Water Division Monthly Report February 2018

Production

	2018	2017	Difference
Total Water Production (MG)	228.071	157.516	70.56
Surface Water (MG)	183.69	112.898	70.79
Groundwater (MG)	44.381	44.618	-0.24
Surface Water Percentage (%)	80.5	71.7	8.80
Sodium Hypochlorite Usage (lbs)	4,116	3,200	916
Average Chlorine Residual (mg/L)	1.39	1.07	0.32

Distribution

	2018	2017	Difference
New Meter Installs	48	15	33
Meter Retrofits	328	300	28
Meter Rereads	244	295	-51
Leaks Repaired	7	10	-3
Valves Exercised	165	220	-55
Backflows Tested	0	0	0

Customer Service

	2018	2017	Difference
Customer Service Requests	21	12	9
Water Quality Compliants	2	6	-4
Sprinkler Timer Service	7	1	6
Service On / Off	1,732	1,179	553
Returned Check Notices	15	9	6

Personnel

	2018	2017	Difference
Sick Leave (Hrs. Used)	114.5	104.75	9.75
Vacation (Hrs. Used)	193.5	415.5	-222
CTO (Hrs. Used)	200.75	94.75	106
Emergency Call Outs	16	17	-1
Injuries	0	0	0
Accidents	0	0	0