



CITY OF MANTECA

PUBLIC WORKS DEPARTMENT WATER DIVISION

Water Division Monthly Report January 2018

Production

	2018	2017	Difference
Total Water Production (MG)	211.039	168.806	42.23
Surface Water (MG)	180.28	106.07	74.21
Groundwater (MG)	30.759	62.736	-31.98
Surface Water Percentage (%)	85.43	62.8	22.63
Sodium Hypochlorite Usage (lbs)	3,367	5,044	-1,677
Average Chlorine Residual (mg/L)	1.64	1.21	0.43

Distribution

	2018	2017	Difference
New Meter Installs	75	53	22
Meter Retrofits	175	52	123
Meter Rereads	356	196	160
Leaks Repaired	10	9	1
Valves Exercised	100	116	16
Backflows Tested	0	0	0

Customer Service

	2018	2017	Difference
Customer Service Requests	39	22	17
Water Quality Compliants	1	1	0
Sprinkler Timer Service	0	1	-1
Service On / Off	1,901	1,311	590
Returned Check Notices	8	22	-14

Personnel

	2018	2017	Difference
Sick Leave (Hrs. Used)	73	122.5	-49.5
Vacation (Hrs. Used)	172.5	186.75	-14.25
CTO (Hrs. Used)	200.5	166.75	33.75
Emergency Call Outs	25	8	17
Injuries	0	0	0
Accidents	0	0	0